



Reinstated Subsoil

Cable Warning Tape

Plastic Cable Covers

Fibre Optic Cable Duct

CBS SURROUND

500 mm Earth Continuity Conductor

290 mm


400 mm

8 mm dia Duct for DTS

1100 mm

600 mm

LEGEND

Reinstated Subsoil 

All 400kV cables shall be installed to the following minimum depths, whether they are rung above or installed in suitable ducts:
Footways, grass verges or private property = 600mm.
Carriageways (including road crossings) = 900mm.
Normal agricultural land (not subject to deep ploughing) = 1050mm.
Agricultural land subject to deep ploughing = 1200 mm.

NOTE:
- Additional 1 metre should be allowed either side for construction.
- Do not scale from this drawing.
- This drawing is to be read in conjunction with all relevant drawings and specifications associated with this project.
- This drawing is indicative and not for construction.

00	22/08/24	FOR INFORMATION	ST	JMB	BP
Rev.	Date	Amendment Details	Drw'n	Chk'd	App'd

This drawing should not be relied on or used in circumstances other than those for which it was originally prepared and for which TNEI Services Ltd was commissioned. TNEI Services Ltd accepts no responsibility for this drawing to any party other than the person by whom it was commissioned. Any party which breaches the provisions of this disclaimer shall indemnify TNEI Services Ltd for all loss or damage arising therefrom.



FOR INFORMATION

NEILSTON GREENER GRID PARK SECTION 36 APPLICATION

INDICATIVE CABLE ROUTE CROSS - SECTION

Scale	1:10	Designed	ST	Drawn	ST	Checked	JMB	Approved	BP
Original Size	A3	Date	22/08/24	Date	22/08/24	Date	22/08/24	Date	22/08/24
Drawing Number	15957-031							Revision	0

